

CERTIFICATE OF COMPLIANCE

Certificate Number 20191122-E204286
Report Reference E204286- 20050411
Issue Date 2019-NOVEMBER-22

Issued to: K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, 42279 Wuppertal GERMANY

**This certificate confirms that
representative samples of**

PROXIMITY SWITCHES

Enclosed Type, Reed Proximity Switches, Model BNS-B20, may be followed by 12Z, -12ZG, -02Z or -02ZG, Follow by -L, -R, -H, ST-L or ST-R, may be follow by -LST, may be followed by numbers and/or letters.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 60947-1 Standard for Low- Voltage Switchgear and Controlgear
CSA C22.2 No. 60947-1-13, Part 1 General Rules and part 5-2-14

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

