



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305668646

NAME AND ADDRESS OF THE APPLICANT

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

NAME AND ADDRESS OF THE MANUFACTURER

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

NAME AND LOCATION OF THE FACTORY

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

PRODUCT NAME,MODEL AND SPECIFICATION

Door Switch

AZ415-...; Uimp:4kV; Ui:250V; Ith:6A; Ue/Ie:AC-15:AC230V/4A, DC-13:DC24V/4A; IP65 or IP67

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Aug.01,2024

Valid until: Jul.31,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010305668646

Appendix : Page 1 of 2

Type description :

AZ415-(1)(2)P(3)K-(4)-(5)

	Option	Explanations
(1)	33	3NO / 3NC contact
	02/11	S1: 2NC, S2: 1NO / 1NC contact
	02/02	S1: 2NC, S2: 2NC contact
	02/20	S1: 2NC, S2: 2NO contact
	11/11	S1: 1NO / 1NC, S2: 1NO / 1NC
(2)	Y	IP 65
	Z	IP 67
(3)	Blank	Standard
	D	for double doors
(4)	Blank	Cable entry M20
	M20	Cable entry M20
(5)	Blank	Standard
	××××-× ×	Indicator for minor customer -specific design change, without change for function or structure
	2537-1	Version with additional push button
		Not all combinations are available

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010305668646

Appendix : Page 2 of 2


Description of special structure (if necessary) :

Enclosure A: 85×104×46mm is for types with "x×/yy" contact arrangement

Enclosure B: 130×100×46mm is for types with "33" contact arrangement but for single actuator (unlike enclosure D)

Enclosure C: 130×100×64,5mm (without Push button) is for single type with push button (2537-1)

Enclosure D: 141×125×46mm is for types suited for double actuators "ZPDK"



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.