



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305669753

NAME AND ADDRESS OF THE APPLICANT

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

NAME AND ADDRESS OF THE MANUFACTURER

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

NAME AND LOCATION OF THE FACTORY

Schmersal India Pvt. Ltd.
G-7/1, MIDC; Ranjangaon, Tal. Shirur, Dist. Pune – 412 220 Maharashtra, India

PRODUCT NAME, MODEL AND SPECIFICATION

Safety Interlock Switch
TZF..., TZM... : Ith: 4A ; Ui: 250V ; Ue/Ie: AC-15: 230V/4A, DC-13: 24V/4A ; IP67 , IP65(N version)

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Aug.02,2024

Valid until: Aug.01,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305669753

Appendix : Page 1 of 2

本翻译文件不具有法律效力，不得单独使用
This translated document does not have legal validity and cannot be used in isolation

Type description:

Ordering Code = TZ(1)(2)(3)(4)(5)(6)(7)-(8)

No.	Option	Description	Remark
(1)	F	Power to Unlock	
	M	Power to Lock	
(2)	Blank	Monitoring of solenoid: 1 NC Monitoring of actuator: 1 NC + 1 NO	
	C	Monitoring of solenoid 1 NC + 1 NO Monitoring of actuator: 1 NC + 1 NO	
	2MOE	Monitoring of solenoid: 2 NC Monitoring of actuator: 1 NC + 1 NO	
	3OE/1S	Monitoring of solenoid: 1 NC Monitoring of actuator: 2 NC + 1 NO	1 NC solenoid + 1 NC actuator in series with removable jumper
	3OE	Monitoring of solenoid: 1 NC Monitoring of actuator: 2 NC+1 NO	
	4OE	Monitoring of solenoid: 2 NC Monitoring of actuator: 2 NC	
	(3)	Blank	Standard type
W		No wiring in series of the NC contacts	
(4)	Blank	No manual release	
	S	Manual release using triangular key	
	SP	Manual release using triangular key and rod	
	S.NF	Manual release and escape release	
	N	Emergency release	
	NE	Manual release using connecting rod with handle	
	NEM	Manual release using connecting rod with nut	
	NEM.CHI	Manual release using connecting rod with nut , customer-specific actuation	
(5)	Blank	Standard type	
	L	with LED indication (only 24 VDC)	

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010305669753

Appendix : Page 2 of 2

(6)	24VDC	Supply Voltage 24 VDC	
(7)	Blank	Standard type	
	BU	With mounting plate	
	RH	Triangular key on chain	
	DM	With additional insulating hose	
	J	Customized packaging (additional polybag)	
(8)	Blank	Standard type	
	xxxx-xx	Indicator for minor customer-specific design change, without change for function or structure; e.g. 2917: without actuator	

Not all combinations are available

Note 1: Options (2) to (7) may be in a different order

Note 2: Slashes "/" and/or dots "." may be used in Ordering Code between different features.

They do not have a technical meaning; they are only used for better readability



This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.