



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305669671

NAME AND ADDRESS OF THE APPLICANT

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

NAME AND ADDRESS OF THE MANUFACTURER

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

NAME AND LOCATION OF THE FACTORY

K.A. Schmersal GmbH & Co. KG
Moeddinghofe 30, D-42279 Wuppertal, Germany

PRODUCT NAME,MODEL AND SPECIFICATION

Limit Switch

T. 454 : Ui:500V;Uimp:6kV;AC-15:Ue/Ie:230VAC/4A;DC-13:Ue/Ie:24VDC/1A;Ith:10A ; IP66,IP67 ;

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Aug.02,2024

Valid until: Aug.01,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2024010305669671

Appendix : Page 1 of 1

Type description :

Ordering Code 454 Series:

T(1) 454-(2)Z-(3)-(4)

No.	Option	Description	描述
(1)	“ “ (=“dot”)	Switch without actuator	开关不带操作件
(2)	11	1 Normally open contact, 1 Normally closed contact	1 常开, 1 常闭触点
	22	2 Normally open contacts, 2 Normally closed contacts	2 常开, 2 常闭触点
	02	2 Normally closed contacts	2 常闭触点
	20	2 Normally open contacts	2 常开触点
	13	1 Normally open contact, 3 Normally closed contacts	1 常开, 3 常闭触点
	31	3 Normally open contact, 1 Normally closed contacts	3 常开, 1 常闭触点
(3)	Blank	Standard product	标准产品
	H	Staggered contacts	非同步触头
(4)	Blank	Standard product	标准产品
	XXXX-XX:	Indicator for minor customer -specific design change, without change for function or structure	针对客户特殊需求, 不改变产品结构和功能

Not all combinations are available
并非所有组合都可用。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.